

# VILLA MALL

Alamosa, CO

# Gibsons, Town-n-Country Mobile Home Park Complex - 1970's



# Gibson's Discount Store






# Fan - Coil Unit
















## Main Building Assessment

A survey of the existing geothermal heating system was conducted mid-January 2009 when the heating requirements of the building were relatively high.

- Water enters building heating system at 112°F
- Water exits building heating system at 106°F
- Average 40 gallons per minute (gpm) flowing through entire system
- Outside air temperature, Min -6°F, Max 28°F, average 11°F

$$\blacksquare \quad 120,168 \text{ Btu/h} = 20,028 \text{ lbs/hr} * 1 \text{ Btu/lb } ^\circ\text{F} * (106 \text{ } ^\circ\text{F} - 112 \text{ } ^\circ\text{F})$$

<b>Btu/ft<sup>2</sup></b>	<b>Estimated Total Heat Energy Required (Btu/h)</b>	<b>Energy Supplied by Warm Geothermal Water (Btu/h)</b>	<b>Estimated Energy Deficit (Btu/h)</b>
5	200,000	120,168	79,832
10	400,000	120,168	279,832
15	600,000	120,168	479,832
20	800,000	120,168	679,832
25	1,000,000	120,168	879,832

Table 3 – Heating capacity estimate of sample fan-coil unit

<b>McQuay TSC081 Fan-Coil</b> <b>Heat Output</b> Heater Fan Setting – High			Entering Air	68°F
			Entering Water	112°F
			Temp Differential ( $\Delta T$ )	44°F
<b>Flow Rate</b>				
Volume Flow (gpm)	Velocity (ft/sec)	Base Rating	Sensible Heating Capacity (Btu/h)	
0.5	0.817	216	9,504	
1	1.634	334	14,696	
1.5	2.451	357	15,708	
2	3.268	453	19,932	
3	4.902	513	22,572	
4	6.536	539	23,716	
5	8.170	565	24,860	
6	9.084	584	25,696	
7	11.438	593	26,092	


Table 5 – Relationship between water flow rate and exiting water temperature of Heater 2

Observed Water Temp In (°F) = 105			Observed Water Temp Out (°F) = 92		
Volume Flow (gpm)	Flow Rate (fps)	Water Mass (lb/h)	Sensible Heat (Btu/h)	Predicted Water Temp Out (°F)	Change in Water Temp - ΔT (°F)
0.5	0.82	250.4	7,992	73	32
1	1.63	500.7	12,358	80	25
1.5	2.45	751.1	13,209	87	18
2	3.27	1001.4	16,761	88	17
3	4.90	1502.1	18,981	92	13
4	6.54	2002.8	19,943	95	10
5	8.17	2503.5	20,905	97	8
6	9.80	3004.2	21,608	98	7
7	11.44	3504.9	21,941	99	6

(Specific Heat of Water (Btu/lb °F) = 1)

- $$\text{Water Temp Out (°F)} = (-\text{Sensible Heat (Btu/h)} / \text{Specific Heat of Water (Btu/lb °F)} * \text{Water Mass (lb/h)}) + \text{Water Temp In (°F)}$$

# Water Volume Flow Relationship to Heat Output and Discharge Water Temperature



## Evidence Supporting Semi-Recirculating System

Table 6 – Heating performance of individual fan-coil unit utilizing re-circulated water



<b>McQuay TSC081 Fan-Coil Heat Output</b>  Heater Fan Setting - High			1 <sup>st</sup> Pass		2 <sup>nd</sup> Pass	
			Entering Air	68°F	Entering Air	68°F
			Entering Water	112°F	Entering Water	106°F
			$\Delta T$	44°F	$\Delta T$	38°F
Flow Rate		Base Rating	Sensible Heating Capacity (Btu/h)	Sensible Heating Capacity (Btu/h)		
Volume Flow (gal/min)	Velocity (ft/sec)					
0.5	0.817	216	9,504	8,208		
1	1.634	334	14,696	12,692		
1.5	2.451	357	15,708	13,566		
2	3.268	453	19,932	17,214		
3	4.902	513	22,572	19,494		
 4	6.536	539	23,716	20,482		
 5	8.170	565	24,860	21,470		
6	9.804	584	25,696	22,192		
7	11.438	593	26,092	22,534		

Table 7: Example of stable water temperature of one fan-coil unit at 50% recycle rate

**Constants**

Volume Flow (gpm)	2
Percent Water from Well	50%
Percent Re-Circulated Water	50%
Mass of Water (lb/h)	1001.4
Source Water Temperature (°F)	112
Fan-Coil Base Rate (from manufacturer reference)	453
Ambient Air Temp (°F)	68

Iteration Cycle	Starting Water Temperature (°F)	Mixed Water Temperature (°F)	Air / Water $\Delta T$ (°F)	Sensible Heating Capacity (Btu/h)	Returning Water Temp (°F)
1	112	112.0	44	19932	92.1
2	92	102.0	34	15424	86.6
3	87	99.3	31	14189	85.2
4	85	98.6	31	13851	84.7
5	85	98.4	30	13759	84.6
6	85	98.3	30	13733	84.6
7	85	98.3	30	13726	84.6
8	85	98.3	30	13725	84.6
9	85	98.3	30	13724	84.6
10	85	98.3	30	13724	84.6
11	85	98.3	30	13724	84.6
12	85	98.3	30	13724	84.6
13	85	98.3	30	13724	84.6
14	85	98.3	30	13724	84.6

Table 8 – Mixed water temperature and heating capacity at various recycle ratios

Water Recycled		Mixed Water Temperature (°F)	Sensible Heating Capacity (Btu/h)	Returning Water Temperature (°F)	Heating Capacity Retained	Heating Capacity Loss
gpm	%					
0	0%	112.0	398,640	92.1	100%	0%
4	10%	109.9	379,560	90.9	95%	5%
8	20%	107.5	358,140	89.6	90%	10%
12	30%	104.9	333,900	88.2	84%	16%
16	40%	101.8	306,280	86.5	77%	23%
20	50%	98.3	274,480	84.6	69%	31%
24	60%	94.2	237,500	82.4	60%	40%
28	70%	89.4	193,940	79.7	49%	51%
32	80%	83.7	141,900	76.6	36%	64%
36	90%	76.7	78,600	72.8	20%	80%
40	100%	68.0	0	68.0	0%	100%

**Retained Heating Capacity at Various Water Recycle Rates**

**Figure 2**




Table 9 illustrates the substantial water savings possible by utilizing a semi re-circulation design.

Table 9 – Water usage and potential savings at various discharge rates

<b>Fill Rate (gpm)</b>	<b>Circulation Rate (gpm)</b>	<b>Discharge Rate (gpm)</b>	<b>Gallons Used per Day</b>	<b>Water Savings</b>	<b>Gallons Saved per Day</b>	<b>Acre Feet Save per Month</b>
40	40	40	57,600	0%	0	0
30	40	30	43,200	25%	14,400	1.33
20	40	20	28,800	50%	28,800	2.65
10	40	10	14,400	75%	43,200	3.98
0	40	0	0	100%	57,600	5.30

Table 10 – Estimated cost of equivalent energy commodities

	<b>Btu/h Rate</b>	<b>Natural Gas (per month)</b>	<b>Electricity (per month)</b>
Observed	120,168	\$371.04	\$720.62
Maximum	400,000	\$1,190.14	\$2,331.78

Table 11 – Current system improvement options

Option	Estimated Cost	Benefit	Disadvantage
Do Nothing	\$0	No expenditure	Continue to struggle with poor heat distribution in building and excessive discharge water
Balance Water Flow	\$3,490	Improved warm water distribution to all heat units. Reduced erosion of plumbing system. Increase occupant comfort	Cost
Semi-Recirculation System	\$3,400	Conserve water and reduce discharge	Cost
Convert to Natural Gas System	\$10,000	Closed system, no discharge water to manage	High annual expense to operate. Must still balance flow and construct re-circulation system
Ground Re-injection System	\$70,000	Discharge water is returned to aquifer	Extremely expensive to develop. Water must be treated. Complicated regulations and expensive system monitoring









